

# DSA-810 - LOCAL FIRE AUTHORITY REVIEW TEMPLATE

For instructions, see [DSA-810.INSTR](#)

## **LOCAL FIRE AUTHORITY REVIEW**

Local Fire Authority to initial the items as applicable to this project and sign below.

**YES NO N/A**

DSA Application #: \_\_\_\_\_

### **Elevators**

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------

Elevators that do not have cabs sized per 2010 California Building Code (CBC) requirements have been identified and the Local Fire Authority approves the use of stairways for emergency rescue and patient transport.

### **Access Roads, Fire Hydrants, and Wildland Urban Interface (WUI)**

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------

Access Roads and Gate Entrances are in accordance with Title 19, Calif. Code of Regulations - Access Roads & 2010 California Fire Code (CFC) - Gate Entrances to school sites.

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------

Fire Flow, Fire Hydrant location and distribution are in accordance with 2010 CFC and/or NFPA 1142.

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------

Wildland Urban Interface Area? (2010 CBC Chapter 7A).

### **Automatic Fire Sprinkler Systems (AFSS)**

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------

The location(s) of the proposed Post Indicator Valve (PIV) and Fire Dept. Connection (FDC) meets the requirements of this jurisdiction.

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------

The location(s) of the Detector Check Valve Assembly (DCVA) meet the requirements of this jurisdiction.

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------

The fire pump assembly/backflow preventer and other valves meet the requirements of this jurisdiction.

## **LOCAL FIRE AUTHORITY INFORMATION**

AGENCY NAME (Print): \_\_\_\_\_

ADDRESS (Print): \_\_\_\_\_

CITY/STATE/ZIP (Print) : \_\_\_\_\_

PHONE NUMBER (Print): \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVAL ISSUED BY: \_\_\_\_\_

(Print name and Sign)

RANK/TITLE (Print): \_\_\_\_\_

COMMENTS (Print): \_\_\_\_\_


Initials and a signature above signify that the Local Fire Authority has reviewed the listed items and was consulted regarding their placement and design. The current configuration shown on this site plan, as of this date, meets with their current standards. Local Stamps w/signature indicates all items above have been reviewed.